




CHECKED AND CERTIFIED BY
 MDACHI GENERAL SUPPLIES
 P.O. BOX 17142 DSM, TEL: 0712 868073
 0588 811 227 DAR ES SALAAM

SERVICES DUE October 2022
 NEXT SERVICES 10 October 2023


CLIENT: _____ SIGNATURE _____

MFZL6 ABC Dry Powder (6kg)


1. Shake cylinder more times




Pull safety pin



2. Aim nozzle at base of fire



3. Squeeze handle



Swing side to side

Common Solids	Flammable Solids	Flammable Liquids	Flammable Gases	Electrical Equipment

INSTRUCTIONS

1. Fire extinguishing agent: Ammonium phosphate
2. Capacity: 6 ± 0.1kg
3. Fire rating: 8/89
4. Working temperature: -20°C - 50°C
5. Discharge gas: Nitrogen at 1.20MPa
6. Every refilled or 1 year after the extinguisher is used or damaged by the operation of pouring. 1.1 Max. service pressure: 2 years.
7. Check up this fire extinguisher regularly. It must be refilled once a discharging or the pressure gauge fail to red area.

ISO 9001 APPROVED

MADE IN CHINA